

April 26, 2016

via email hunnes@facnet.ucla.edu

Mr. Eric Hunnes  
Facilities Management  
University of California  
731 Charles Young Drive  
Los Angeles, California 90095-1526

Regarding: Parking Structure 3 Seismic Upgrade – UC Seismic Policy  
Englekirk Job Number 12-G146

Dear Eric,

In May 2011, Englekirk submitted a report presenting the results of a building condition survey and seismic evaluation performed on Parking Structure 3. It was found that the parking structure had a seismic rating of POOR, which is equivalent to a seismic rating of V per the current University of California Seismic Policy, dated July 2011. The University elected to pursue a phased approach to upgrading this structure. The first phase, which was completed, was intended to improve the seismic rating to FAIR or IV.

In 2012, seismic correction work was undertaken based on structural drawings prepared by our firm, dated February 13, 2012. It is our opinion that the completion of this seismic correction work warrants a change in the UCLA Parking Structure 3 seismic rating to IV, which is equivalent to the prior UC Seismic Policy rating of FAIR.

Sincerely,



Vladimir A. Volnyy, SE, PE  
Associate Principal

VV:klc

888 S. Figueroa Street  
18<sup>th</sup> Floor  
Los Angeles, CA 90017

323.733.6673 T

www.englekirk.com

Los Angeles  
Orange County  
San Diego  
Honolulu  
Guam  
China

Tony Ghodsi, SE  
Lawrence Y. Ho, SE  
Michael K. Kawaharada, SE  
Christopher Rosien  
Thomas A. Sabol, PhD, SE  
Russell Tanouye, SE, LEED AP  
Diana Erickson Nishi, SE  
Vladimir A. Volnyy, SE  
Al Ikemura  
Thomas Y. Nishi, SE  
Alan T. Shiosaki, SE  
Mahmoud Faghghi, SE  
Ety Benichou, SE  
Mohamed Hassan, PhD, SE  
Zen Hoda, SE  
Gabriel Jugo, SE  
Katherlin Lee-Choi  
Milton S. Shiosaki  
Daniel W. Shubin  
Kimberly F. Tanouye