



ENGLEKIRK & SABOL
Consulting Structural Engineers, Inc.

January 7, 2004
 Revised January 23, 2004

Via Facsimile (310) 206-1510

Ms. Natalie Shivers
 UCLA Capital Program
 1060 Veteran Avenue, 3rd Floor
 Los Angeles, California 90095

Regarding: UCLA Geffen Playhouse
 Construction Document Submittal Peer Review
 ESI Job No. 03-G154

Dear Natalie:

We have completed our review of the structural drawings and calculations for this project. All of our comments have been addressed by the engineer of record. We note that this building is currently rated "FAIR" based on the University of California Seismic Policy and this project is not intended to raise the building's rating to "GOOD." Our review is based on this understanding.

Englekirk & Sabol Consulting Structural Engineers, Inc. peer review services are performed, within the limits prescribed by our clients, in a manner consistent with that level of similar care and skill ordinarily exercised by other professional consultants under similar circumstances. No other representations to our clients, expressed or implied, and no warranty or guarantee is included or intended in our work product. It is understood that Englekirk & Sabol Consulting Structural Engineers, Inc. is not responsible or liable for the accuracy or adequacy of a structural design performed by others, and that the responsibility for drawings and specifications rests solely with the Owner of the building and the design professional of record for the building.

Should you have any questions regarding our review, please call.

Sincerely,

Thomas A. Sabol, Ph.D., S.E.
 Principal

TAS:la

Robert E. Engelbirt, S.E.
 Tom Gahan, S.E.
 Lawrence P. Ho, S.E.
 Michael K. Karamanidis, S.M.
 Christopher Kauten
 Thomas A. Sabol, S.E.
 Robert S. Sayers, S.E.
 Barry T. Saxe, S.E.
 Al Skouras
 Steve A. Karamanidis, S.E.
 Alan P. Sathian, S.E.
 William A. Williams, S.E.
 Albert J. Fabel, S.E.
 Diane Kirkman Mehl, S.E.
 Kimberly F. Talavera

Los Angeles
 Orange County
 Honolulu

2515 Arlington Avenue
 Los Angeles, CA 90015-1398
 323 733 2840 323 733 5682 fax
 www.englekirk.com



**N
Y**

NABIH YOUSSEF & ASSOCIATES

Structural Engineers

Los Angeles • San Francisco • Irvine • Central Coast

July 11, 2005

Ron Frink
Ronald Frink Architects, Inc.
2439 W. Silver Lake Drive
Los Angeles, CA 90039

**RE: *Geffen Playhouse Renovation & Addition
Existing Roof Tile Anchorage***

Dear Ron:

We have reviewed the letter CRC Consulting Group dated June 23, 2005, regarding the existing roof tile anchorage system. The letter describes the twisted wires passing over the roof ridges as 0.14" diameter stainless steel wires spaced at 12" on center.

The seismic retrofit work shown on the Geffen Playhouse Renovation and Addition structural drawings dated 05/30/04 are intended to reduce the falling hazards in the existing building to insure a seismic rating of "Fair." This rating applies to a building for which a major seismic disturbance is anticipated to resulting in structural and nonstructural falling hazard that would represent low life hazards. Based on the description of the existing tile anchorage system noted above, it is our opinion that the existing as built condition satisfies the seismic rating of "Fair" without additional seismic anchorage of the tiles within 5 feet of the eaves.


Please do not hesitate to contact me if you have any questions.

Sincerely,

NABIH YOUSSEF & ASSOCIATES



Jim Zeiner, S.E.
Project Manager



Nabih Youssef, S.E.
Structural Engineer of Record

Xc: File # 02672.20