

Our ref 31671/cw
Date February 12, 2002

Bill C.
2440 South Sepulveda Boulevard
Suite 180
Los Angeles CA 90064
Tel +1 310 312 5040
Fax +1 310 312 5788
catherine.wells@arup.com

www.arup.com

CC: Kathy F
Bill C
Natalie S.

Curt Ginther
UCLA
Capital Programs
1060 Veteran Avenue
Los Angeles, CA 90095

ARUP

Dear Curt

**UCLA Kaufman Hall
Seismic Peer Review**

We have completed our seismic peer review of the above project for compliance with the GOOD seismic performance rating which is defined in the University Policy on Seismic Safety:

“GOOD seismic performance rating would apply to buildings and other structures whose performance during a major seismic disturbance is anticipated to result in some structural and/or non-structural damage and/or falling hazards that would not significantly jeopardize life. Buildings and other structures with a GOOD rating would have a level of seismic resistance such that funds need not be spent to improve their seismic resistance to gain greater life safety and would represent an acceptable level of earthquake safety.”

It is our professional opinion that the approach to the design of the structural upgrade of UCLA Kaufman Hall is consistent with this criterion.

Please let us know if we can be of further assistance.

Yours sincerely



Catherine Wells
Associate Principal

Feb 11 1 59 PM '02
UCLA