

September 12, 2014

Mr. Eric T. Heggen
UCLA Capital Programs
1060 Veteran Avenue
Los Angeles, CA 90095-1365

Re.: **UCLA Life Sciences Building**
Completion of Construction/Seismic Rating

Dear Mr. Heggen:

To the best of our knowledge, construction of the seismic strengthening at the UCLA Life Sciences Building has been completed in accordance with the structural drawings dated April 19th, 2013; along with Bulletin #3 Field Revisions issued April 8th 2014. The seismic work was included as part of the Fire and Life Safety Upgrade (UCLA project #943525.01) and consisted of the reinforcing of the four existing concrete columns located adjacent to Charles Young Dr. with carbon fiber column jackets.

With the completion of construction of the seismic strengthening in accordance with the structural drawings noted above, the Life Sciences Building now qualifies for a seismic rating of **IV ("Fair")** according to the UC Seismic Safety Policy.

Please do not hesitate to contact us if you have any questions.

Sincerely,

NABIH YOUSSEF ASSOCIATES



Kelly Weldon, S.E.
Project Manager



Nabih Youssef, S.E.
Principal

Xc: Cliff Peterson, Studios Architecture
NYA File #11247.00