

October 1, 2012

via email hunnes@facnet.ucla.edu

Mr. Eric Hunnes
Facilities Management
University of California
731 Charles Young Drive
Los Angeles, California 90095-1526

Regarding: Parking Structure 9 Seismic Upgrade – UC Seismic Policy
Englekirk Job Number 11-G149

Dear Eric,

In May 2011, Englekirk submitted a report presenting the results of a building condition survey and seismic evaluation performed on Parking Structure 9. It was found that the parking structure had a seismic rating of POOR, which is equivalent to a seismic rating of V per the current University of California Seismic Policy, dated July 2011. The University elected to pursue a phased approach to upgrading this structure. The first phase, which is essentially complete, was intended to improve the seismic rating to FAIR or IV.

In 2012, seismic correction work was undertaken based on structural drawings prepared by our firm, dated February 13, 2012. It is our opinion that the completion of this seismic correction work warrants a change in the UCLA Parking Structure 9 seismic rating to IV, which is equivalent to the prior UC Seismic Policy rating of FAIR.

Sincerely,



Thomas A. Sabol, Ph.D., S.E.
Principal

TAS:kic

2716 Arlington Avenue
Los Angeles, CA 90018-1398

323.733.6673 T
323.733.8682 F

www.englekirk.com

Los Angeles
Orange County
San Diego
Portland
Tampa
Dallas

Robert E. Englekirk, Ph.D., SE
Tony Ghodr, SE
Lawrence Y. Ho, SE
Michael K. Kawaharada, SE
Christopher Rossini
Thomas A. Sabol, Ph.D., SE
Russell Tanouya, SE, LLED AP
Al Ikemura
Diana Erickson Nishi, SE
Alan T. Shiosaki, SE
Richard Ebon, SE
Gabriel Jugo, SE
Katherine Lee-Choi
Thomas Y. Nishi, SE
Milton S. Shiosaki
Daniel H. Stubbs
Kimberly F. Tanouya
Vladimir A. Volnyy, SE