



**FORM 1**  
**CERTIFICATE OF SEISMIC PERFORMANCE LEVEL**

- UC-Designed & Constructed Facility**  
 **Campus-Acquired or Leased Facility**

**BUILDING DATA**

Building Name: [Public Affairs Arts Library](#)  
Address: [337 Charles E Young Dr E, Los Angeles, CA 90095](#)  
Site location coordinates: Latitude [34.0745](#) Longitudinal [-118.4393](#)

**UCOP SEISMIC PERFORMANCE LEVEL (OR "RATING"): [V](#)**

ASCE 41-17 Model Building Type:

- a. Longitudinal Direction: [C2: Concrete Shear Walls with Stiff Diaphragms](#)
- b. Transverse Direction: [C2: Concrete Shear Walls with Stiff Diaphragms](#)

Gross Square Footage: [15,928](#)  
Number of stories *above* grade: [2](#)  
Number of basement stories *below* grade: [1](#)

Year Original Building was Constructed: [1959](#)  
Original Building Design Code & Year: [UBC 1958](#)  
Retrofit Building Design Code & Code (if applicable): [N/A, N/A](#)

**SITE INFORMATION**

Site Class: [D](#) Basis: ([GeoPentech, 2/22/2019, 10](#))  
Geologic Hazards:  
Fault Rupture: [No](#) Basis: { }  
Liquefaction: [No](#) Basis: { }  
Landslide: [No](#) Basis: { }

**ATTACHMENT**

Original Structural Drawings: ([Graduate School of Business Administration, Hillman & Nowell, 6/1/1959, N/A](#)) or  
Seismic Evaluation: ([Seismic Evaluation of the UCLA Public Affairs Buildings, KPFF, September 21, 2018, ASCE 41-13 Tier 3](#))  
Retrofit Structural Drawings: [N/A](#)



### CERTIFICATION

I, [Mark Hershberg](#), a California-licensed structural engineer, am responsible for the completion of this certificate, and I have no ownership interest in the property identified above. My scope of review to support the completion of this certificate included both of the following:

- a) the review of structural drawings indicating that they are as-built or record drawings, or that they otherwise are the basis for the construction of the building:  Yes  No
- b) visiting the building to verify the observable existing conditions are reasonably consistent with those shown on the structural drawings:  Yes  No

Based on my review, I have verified that the UCOP Seismic Performance Level is presumptively permitted by the following UC Seismic Program Guidebook provision (choose one of the following):

- 1) Contract documents indicate that the original design and construction of the aforementioned building is in accordance with the benchmark design code year (or later) building code seismic design provisions for UBC or IBC listed in Table 1 below.
- 2) The existing SPL rating is based on an acceptable basis of seismic evaluation completed in 2006 or later.
- 3) Contract documents indicate that a comprehensive<sup>1</sup> building seismic retrofit design was fully-constructed with a design completed in 2000 or later, and that design was based on ground motion parameters, at a minimum, corresponding to:
  - BSE-1E (or BSE-R) and BSE-2E (or BSE-C) as defined in ASCE 41, or the full design basis ground motion required in the 1997 UBC/1998 CBC **or later** for EXISTING buildings, and is presumptively assigned an SPL rating of IV.
  - BSE-1 (or BSE-1N) and BSE-2 (or BSE-2N) as defined in ASCE 41, or the full design basis ground motion required in the 1997 UBC/1998 **or later** CBC for NEW buildings, and is presumptively assigned an SPL rating of III.

AFFIX SEAL HERE

Mark Hershberg  
Print Name

Principal  
Title

S5078  
CA Professional Registration No.

6/30/2021  
License Expiration Date

  
Signature

27 Jun 2019  
Date



KPFF Consulting Engineers, (213) 418-0201  
700 S Flower St., Suite 2100, Los Angeles, CA 90017

<sup>1</sup> A comprehensive retrofit addresses the entire building structural system as indicated by the associated seismic evaluation, as opposed to addressing selective portions of the structural system.



KPFF Consulting Engineers, (213) 418-0201 700 S Flower St., Suite 2100, Los Angeles, CA 90017

**Table 1: Benchmark Building Codes and Standards**

| Building Type <sup>a,b</sup>  | Building Seismic Design Provisions |      |
|---|------------------------------------|------|
|   | UBC                                | IBC  |
| Wood frame, wood shear panels (Types W1 and W2)                                 | 1976                               | 2000 |
| Wood frame, wood shear panels (Type W1a)  | 1976                               | 2000 |
| Steel moment-resisting frame (Types S1 and S1a)                                 | 1997                               | 2000 |
| Steel concentrically braced frame (Types S2 and S2a)                            | 1997                               | 2000 |
| Steel eccentrically braced frame (Types S2 and S2a)                             | 1988 <sup>g</sup>                  | 2000 |
| Buckling-restrained braced frame (Types S2 and S2a)                             | f                                  | 2006 |
| Metal building frames (Type S3)   | f                                  | 2000 |
| Steel frame with concrete shear walls (Type S4)                                 | 1994                               | 2000 |
| Steel frame with URM infill (Types S5 and S5a)                                  | f                                  | 2000 |
| Steel plate shear wall (Type S6)  | f                                  | 2006 |
| Cold-formed steel light-frame construction—shear wall system (Type CFS1)        | 1997 <sup>h</sup>                  | 2000 |
| Cold-formed steel light-frame construction—strap-braced wall system (Type CFS2) | f                                  | 2003 |
| Reinforced concrete moment-resisting frame (Type C1) <sup>i</sup>               | 1994                               | 2000 |
| Reinforced concrete shear walls (Types C2 and C2a)                              | 1994                               | 2000 |
| Concrete frame with URM infill (Types C3 and C3a)                               | f                                  | f    |
| Tilt-up concrete (Types PC1 and PC1a)   | 1997                               | 2000 |
| Precast concrete frame (Types PC2 and PC2a)                                     | f                                  | 2000 |
| Reinforced masonry (Type RM1)   | 1997                               | 2000 |
| Reinforced masonry (Type RM2)   | 1994                               | 2000 |
| Unreinforced masonry (Type URM)   | f                                  | f    |
| Unreinforced masonry (Type URMa)  | f                                  | f    |
| Seismic isolation or passive dissipation  | 1991                               | 2000 |

Note: This table has been adapted from ASCE 41-17 Table 3-2. Benchmark Building Codes and Standards for Life Safety Structural Performed at BSE-1E.

Note: UBC = Uniform Building Code . IBC = International Building Code .

<sup>a</sup> Building type refers to one of the common building types defined in Table 3-1 of ASCE 41-17.

<sup>b</sup> Buildings on hillside sites shall not be considered Benchmark Buildings.

<sup>c</sup> not used

<sup>d</sup> not used

<sup>e</sup> not used

<sup>f</sup> No benchmark year; buildings shall be evaluated in accordance with Section III.J.

<sup>g</sup> Steel eccentrically braced frames with links adjacent to columns shall comply with the 1994 UBC Emergency Provisions, published September/October 1994, or subsequent requirements.

<sup>h</sup> Cold-formed steel shear walls with wood structural panels only.

<sup>i</sup> Flat slab concrete moment frames shall not be considered Benchmark Buildings.