

June 4, 2014

Via email: hunnes@facnet.ucla.edu

Mr. Eric Hunnes
Facilities Management
University of California
731 Charles Young Drive
Los Angeles, California 90095-1526


Regarding: West Medical Chiller Plant Seismic Correction
ESI Job Number 13-G108

Dear Eric,

Based on the seismic evaluation report prepared by our firm dated October 20, 2011, the West Medical Chiller Plant was given a Seismic Rating of V per the University of California Seismic Safety Policy dated August 2011.

Seismic correction work was undertaken based on structural drawings prepared by our firm, dated July 18, 2013. This work has been completed and it is our opinion that the completion of this seismic correction work warrants a change in the West Medical Chiller Plant Seismic Rating to III.

Sincerely,



Thomas A. Sabol, Ph.D., S.E.
Principal

TAS:klc

cc: Mahmoud Faghihi / Englekirk

888 S. Figueroa Street
18th Floor
Los Angeles, CA 90017

323.733.6673 T

www.englekirk.com

Los Angeles
Orange County
San Diego
Honolulu
Guam
China

Robert E. Englekirk, PhD, SE
Tony Ghodsi, SE
Lawrence Y. Ho, SE
Michael K. Kawaharada, SE
Christopher Rosien
Thomas A. Sabol, PhD, SE
Russell Tanouye, SE, LEED AP
Diana Erickson Nishi, SE
Vladimir A. Volnyy, SE
Al Ikemura
Thomas Y. Nishi, SE
Alan T. Shiosaki, SE
Mahmoud Faghihi, SE
Rajnikanth Gedhada, SE, LEED AP
Ety Guez, SE
Mohamed Hassan, PhD, SE
Zen Hoda, SE
Gabriel Jugo, SE
Katherlin Lee-Choi
Milton S. Shiosaki
Daniel W. Shubin
Kimberly F. Tanouye