## APPENDIX B

## University of California RTIFICATE OF APPLICABLE CODE FOR CALIFORNIA PROPERTIES

CERTIFICATE OF APPLICABLE CODE FOR CALIFORNIA PROPERTIES  Porter Ranch Medical Building	
Building Address: 19950 Rinaldi St., Porter Ranch California ("Building")	
t, <u>Stephen Wen</u> , AIA an architect, civil engineer, or structural engineer, duly licensed by the State of California,*have completed a walk-through of the Building on and	
reviewed the available documentation of the Building docathod above I horsely partial that the	
design and construction of the entire Building was either: *I am the Architect of Record for the building described above.	
approved by the local jurisdiction pursuant to the 1998 or later edition of the California Code of Regulations, Title 24, Part 2, California Building Code (CBC)	
- OR	
Deproved by the local jurisdiction pursuant to the 1976 or later edition of the Uniform Building Code (UBC), including all additions, modifications or repairs to the selsmic resisting systems. This building was originally constructed in	
I further certify that the Building is not and does not contain any of the following:  (i) unreinforced mesonry walls;  (ii) welded steet moment frames (WSMF) constituting the primary structural system of the building which WSMFs (a) have been subjected to a previous strong ground motion (approximately 0.20g or greater) since construction <sup>2</sup> , or (b) may have low or limited redundancy, or discontinuity, or offsets of the moment frames;  (iii) flexible disphragm-rigid walls;  (iv) apparent additions, or modifications, or repairs to the seismic resisting systems done without a permit;  (v) hillside construction on a slope steeper than 1-vertical to 3-horizontal; or,  (vi) multi-story structure with construction over soft first-story structure.	
I have attached a copy of the certificate of occupancy.	
Print Name Stephen Wen License No. C15631 AFFIX SEAL HERE	
Title Sr Frincipal Signature Date January 27, 2012	×
Signature January 27, 2012	હિંદી
Firm Name and Andress SWA Architects, 48 East Holly St.	*
Pasadena, CA 91103	
Ø NO. C 15631	
The same of the sa	NE.
CALIFE	
As used herein, the use of the word 'certify' by an architect, aiv's engineer, or structural engineer constitutes an expression of protessional opinion regarding those facts or lindings, which are the subject of the certification, and does not constitute a warranty or guarantee, either expressed or implied.  Committy applies to WSMF buildings built before 1998 in the Santa Cruz/San Francisco Bay Area (Lone Printe) and built before 1994 in the Lone Architecture.	
the Los Angeles area (Northiniges). It also applies to SNF buildings in other geographic areas where design and construction was approved prior to the affective date of the 1998 Edition, Calibrate Code of Regulations, Title 24, Calibrate Building Code, that may have been authorized to this level of ground motion in any subsequent carriagulass.	